

MARCH 24, 2006 Amendment to Request for Proposals for FutureGen Facility Host Site

This is an amendment to the final Request for Proposal (RFP) issued on March 7, 2006. The period of time for responding to the RFP is not extended. Proposals are due by 4:00pm Eastern time on May 4, 2006 to the address listed in Section 1.5.10 of the RFP.

1. Criterion 1.4.1 is modified to read as follows:

1.1.4. Seismic Stability. The proposed power plant site must ~~be free of~~ **have low** risk from significant seismic events.

- Required evidence: Provide supporting geological data and calculations demonstrating: **1) peak ground acceleration less than 30 percent g, with a 2 percent chance of exceedance in 50 years, based on USGS seismic hazard data, or 2) a site-specific seismic analysis demonstrating equivalent ground motion hazard. This analysis must include at a minimum an assessment of seismic sources, their characteristics and type, occurrence frequency, and ground-motion attenuation relationships.**